

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002


**C** Tigard-Tualatin SD  
**L** Attn: Phil Wentz  
**I** 6960 SW Sandburg St.  
**E** Tigard OR, 97223  
**N** Phone: (503) 431-4017  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-01</b>	<b>Sample Name:</b> Rm 26 Teach <b>Sampled:</b> 1/4/18 5:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-02</b>	<b>Sample Name:</b> Rm 26 1 <b>Sampled:</b> 1/4/18 5:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-03</b>	<b>Sample Name:</b> Rm 26 2 <b>Sampled:</b> 1/4/18 5:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-04</b>	<b>Sample Name:</b> Rm 26 3 <b>Sampled:</b> 1/4/18 5:38		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-05</b>	<b>Sample Name:</b> Rm 26 4 <b>Sampled:</b> 1/4/18 5:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-06</b>	<b>Sample Name:</b> Rm 26 5 <b>Sampled:</b> 1/4/18 5:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-07</b>	<b>Sample Name:</b> Rm 26 6 <b>Sampled:</b> 1/4/18 5:35		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-08</b>	<b>Sample Name:</b> Rm 27 Teach <b>Sampled:</b> 1/4/18 5:34		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-09</b>	<b>Sample Name:</b> Rm 27 1 <b>Sampled:</b> 1/4/18 5:33		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-10</b>	<b>Sample Name:</b> Rm 27 2 <b>Sampled:</b> 1/4/18 5:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	01/08/18 16:28



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002


**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-11</b>	<b>Sample Name:</b> Rm 27 3 <b>Sampled:</b> 1/4/18 5:31		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-12</b>	<b>Sample Name:</b> Rm 27 4 <b>Sampled:</b> 1/4/18 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-13</b>	<b>Sample Name:</b> Rm 27 5 <b>Sampled:</b> 1/4/18 5:29		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-14</b>	<b>Sample Name:</b> Rm 27 6 <b>Sampled:</b> 1/4/18 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-15</b>	<b>Sample Name:</b> Rm 28 Teach <b>Sampled:</b> 1/4/18 5:27		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-16</b>	<b>Sample Name:</b> Rm 28 1 <b>Sampled:</b> 1/4/18 5:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-17</b>	<b>Sample Name:</b> Rm 28 2 <b>Sampled:</b> 1/4/18 5:25		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-18</b>	<b>Sample Name:</b> Rm 28 3 <b>Sampled:</b> 1/4/18 5:24		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-19</b>	<b>Sample Name:</b> Rm 28 4 <b>Sampled:</b> 1/4/18 5:23		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-20</b>	<b>Sample Name:</b> Rm 28 5 <b>Sampled:</b> 1/4/18 5:22		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002


**C** Tigard-Tualatin SD  
**L** Attn: Phil Wentz  
**I** 6960 SW Sandburg St.  
**E** Tigard OR, 97223  
**N** Phone: (503) 431-4017  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-21</b>	<b>Sample Name:</b> Rm 28 6 <b>Sampled:</b> 1/4/18 5:21		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-22</b>	<b>Sample Name:</b> Rm 29 Teach <b>Sampled:</b> 1/4/18 5:20		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-23</b>	<b>Sample Name:</b> Rm 29 1 <b>Sampled:</b> 1/4/18 5:19		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-24</b>	<b>Sample Name:</b> Rm 29 2 <b>Sampled:</b> 1/4/18 5:18		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	15	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-25</b>	<b>Sample Name:</b> Rm 29 3 <b>Sampled:</b> 1/4/18 5:17		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-26</b>	<b>Sample Name:</b> Rm 29 4 <b>Sampled:</b> 1/4/18 5:16		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-27</b>	<b>Sample Name:</b> Rm 29 5 <b>Sampled:</b> 1/4/18 5:15		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-28</b>	<b>Sample Name:</b> Rm 29 6 <b>Sampled:</b> 1/4/18 5:14		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-29</b>	<b>Sample Name:</b> Rm 30 Teach <b>Sampled:</b> 1/4/18 5:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-30</b>	<b>Sample Name:</b> Rm 30 1 <b>Sampled:</b> 1/4/18 5:12		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	01/15/18 14:01



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002


**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-31</b>	<b>Sample Name:</b> Rm 30 2 <b>Sampled:</b> 1/4/18 5:11		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-32</b>	<b>Sample Name:</b> Rm 30 3 <b>Sampled:</b> 1/4/18 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-33</b>	<b>Sample Name:</b> Rm 30 4 <b>Sampled:</b> 1/4/18 5:09		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-34</b>	<b>Sample Name:</b> Rm 30 5 <b>Sampled:</b> 1/4/18 5:08		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-35</b>	<b>Sample Name:</b> Rm 30 6 <b>Sampled:</b> 1/4/18 5:07		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-36</b>	<b>Sample Name:</b> Science Prep <b>Sampled:</b> 1/4/18 5:06		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-37</b>	<b>Sample Name:</b> Rm 16 Faucet <b>Sampled:</b> 1/4/18 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-38</b>	<b>Sample Name:</b> Rm 21 Faucet <b>Sampled:</b> 1/4/18 5:05		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-39</b>	<b>Sample Name:</b> Rm 24 Teach <b>Sampled:</b> 1/4/18 5:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-40</b>	<b>Sample Name:</b> Rm 24 1 <b>Sampled:</b> 1/4/18 5:39		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9	ppb	2	20 ppb	01/15/18 14:01



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002


**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-41</b>	<b>Sample Name:</b> Rm 24 2 <b>Sampled:</b> 1/4/18 5:38		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-42</b>	<b>Sample Name:</b> Rm 24 3 <b>Sampled:</b> 1/4/18 5:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-43</b>	<b>Sample Name:</b> Rm 24 4 <b>Sampled:</b> 1/4/18 5:36		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-44</b>	<b>Sample Name:</b> Rm 24 5 <b>Sampled:</b> 1/4/18 5:35		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-45</b>	<b>Sample Name:</b> Rm 24 6 <b>Sampled:</b> 1/4/18 5:34		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-46</b>	<b>Sample Name:</b> Science RT fountain <b>Sampled:</b> 1/4/18 5:33		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-47</b>	<b>Sample Name:</b> Science Left fountain <b>Sampled:</b> 1/4/18 5:32		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/08/18 16:28
<b>8004002-48</b>	<b>Sample Name:</b> Stem - faucet <b>Sampled:</b> 1/4/18 5:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	11	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-49</b>	<b>Sample Name:</b> Rm 38 1 <b>Sampled:</b> 1/4/18 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-50</b>	<b>Sample Name:</b> Rm 38 2 <b>Sampled:</b> 1/4/18 4:49		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 01/16/2018  
Received: 01/04/2018  
Sampled By: Wentz  
Work Order: 8004002

**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Fowler MS

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>8004002-51</b>	<b>Sample Name:</b> Rm 38 3						<b>Matrix:</b> Water
	<b>Sampled:</b> 1/4/18 4:48						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01
<b>8004002-52</b>	<b>Sample Name:</b> Rm 38 4						<b>Matrix:</b> Water
	<b>Sampled:</b> 1/4/18 0:00						
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	01/15/18 14:01

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director