

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/08/2017
Received: 11/30/2016
Sampled By: P Wentz
Work Order: 6335009


C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: TTSD - HB - Hazelbrook MS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6335009-01	Sample Name: Health room Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-02	Sample Name: Health room bathroom Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	02/07/17 17:21
6335009-03	Sample Name: Office sink Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	02/07/17 17:21
6335009-04	Sample Name: Office bathroom Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	02/07/17 17:21
6335009-05	Sample Name: Kitchen entry fountain Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-06	Sample Name: Kitchen Bath Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/07/17 17:21
6335009-07	Sample Name: Kitchen food Prep Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	02/07/17 17:21
6335009-08	Sample Name: Gym left fountain Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-09	Sample Name: Gym right fountain Sampled: 11/30/16 4:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-10	Sample Name: Health bubbler Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	7.8	ppb	2.0	20 ppb	02/07/17 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/08/2017
Received: 11/30/2016
Sampled By: P Wentz
Work Order: 6335009


C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: TTSD - HB - Hazelbrook MS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6335009-11	Sample Name: Health faucet Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	7.7	ppb	2.0	20 ppb	02/07/17 17:21
6335009-12	Sample Name: Red locker bath rt sink Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-13	Sample Name: Commons Boys bath rt sink Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-14	Sample Name: Commons Boys staff bath Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	02/07/17 17:21
6335009-15	Sample Name: Commons Girls rt sink Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-16	Sample Name: Commons Girls staff Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	02/07/17 17:21
6335009-17	Sample Name: Staff Workroom Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	41.9	ppb	4.0	20 ppb	02/07/17 17:21 MCLE
6335009-18	Sample Name: Conf 1 Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	8.3	ppb	2.0	20 ppb	02/07/17 17:21
6335009-19	Sample Name: Rm 10 bubbler Sampled: 11/30/16 4:50		Matrix: Water				
+Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/07/17 17:21
6335009-20	Sample Name: Rm 10 faucet Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	02/07/17 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/08/2017
Received: 11/30/2016
Sampled By: P Wentz
Work Order: 6335009


C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: TTSD - HB - Hazelbrook MS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6335009-21	Sample Name: Denali girls bath Rt Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	02/07/17 17:21
6335009-22	Sample Name: Denali boys bath Rt Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-23	Sample Name: Denali staff bath Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	02/07/17 17:21
6335009-24	Sample Name: Denali fountain Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/07/17 17:21
6335009-25	Sample Name: D1 bubbler Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-26	Sample Name: D1 sink Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	9.4	ppb	2.0	20 ppb	02/07/17 17:21
6335009-27	Sample Name: D2 bubbler Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/07/17 17:21
6335009-28	Sample Name: D2 sink Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	02/07/17 17:21
6335009-29	Sample Name: D3 bubbler Sampled: 11/30/16 5:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-30	Sample Name: D3 sink Sampled: 11/30/16 5:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 02/08/2017
Received: 11/30/2016
Sampled By: P Wentz
Work Order: 6335009


**C
L
I
E
N
T**
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: TTSD - HB - Hazelbrook MS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6335009-31	Sample Name: D4 second sink from door Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-32	Sample Name: D4 6th sink from door Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-33	Sample Name: D5 sink Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/07/17 17:21
6335009-34	Sample Name: D5 bubbler Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-35	Sample Name: D6 sink Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	02/07/17 17:21
6335009-36	Sample Name: D6 bubbler Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	02/07/17 17:21
6335009-37	Sample Name: D7 bubbler Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	02/07/17 17:21
6335009-38	Sample Name: D7 sink Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/07/17 17:21
6335009-39	Sample Name: D8 sink Sampled: 11/30/16 5:24		Matrix: Water				
†Lead	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/07/17 17:21
6335009-40	Sample Name: D8 bubbler Sampled: 11/30/16 5:40		Matrix: Water				
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/08/2017
Received: 11/30/2016
Sampled By: P Wentz
Work Order: 6335009

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: TTSD - HB - Hazelbrook MS

Lab Number

Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6335009-41	Sample Name: D9 sink Sampled: 11/30/16 5:40					Matrix: Water
+Lead	1030 EPA 200.9	5.0	ppb	2.0	20 ppb	02/07/17 17:21
6335009-42	Sample Name: D9 bubbler Sampled: 11/30/16 5:42					Matrix: Water
+Lead	1030 EPA 200.9	3.4	ppb	2.0	20 ppb	02/07/17 17:21
6335009-43	Sample Name: Commons fountain Sampled: 11/30/16 5:50					Matrix: Water
+Lead	1030 EPA 200.9	ND	ppb	2.0	20 ppb	02/07/17 17:21
6335009-44	Sample Name: Blue locker Bath Rt sink Sampled: 11/30/16 5:50					Matrix: Water
+Lead	1030 EPA 200.9	2.0	ppb	2.0	20 ppb	02/07/17 17:21

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

