



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 04/05/2017

Received: 03/14/2017

Sampled By:

Work Order: 7073006

C
L
I
E
N
T

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:

Project # : N/A

Sample Type :

Sampling Location: Hazelbrook

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7073006-01	Sample Name: Teacher's workroom F		Matrix: Water				
	Sampled: 3/7/17 6:15						
+Lead	1030	EPA 200.9	168	ppb	20.0	20 ppb	04/04/17 16:44 MCLE
7073006-02	Sample Name: Teacher's workroom F Flush		Matrix: Water				
	Sampled: 3/7/17 6:15						
+Lead	1030	EPA 200.9	24.6	ppb	2.0	20 ppb	04/04/17 16:44 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

