

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 11/09/2016
Sampled By: P. Wentz
Work Order: 6314003

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Woodward

Lab Number


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6314003-01	Sample Name: Gym Fountain Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-02	Sample Name: Rm 23 bubbler Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-03	Sample Name: Rm 23 faucet Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	8.4	ppb	2.0	20 ppb	12/14/16 16:30
6314003-04	Sample Name: Rm 18 bubbler Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-05	Sample Name: Rm 18 faucet Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-06	Sample Name: Rm 7 bubbler Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-07	Sample Name: Rm 7 faucet Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30
6314003-08	Sample Name: Rm 2 faucet Sampled: 11/9/16 4:20		Matrix: Water				
+Lead	1030	EPA 200.9	82.2	ppb	8.0	20 ppb	12/14/16 16:30 MCLE
6314003-09	Sample Name: Rm 2 bubbler Sampled: 11/9/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	122	ppb	8.0	20 ppb	12/14/16 16:30 MCLE

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016

Received: 11/09/2016

Sampled By: P. Wentz

Work Order: 6314003

C **Tigard-Tualatin SD**
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T


Project:
Project # : N/A
Sample Type :

Sampling Location: Woodward

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director