

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017
Received: 01/31/2017
Sampled By:
Work Order: 7031003

C **Tigard-Tualatin SD**
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Woodward

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
7031003-01	Sample Name: 26 B Boys Faucet R Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-02	Sample Name: 26 B Staff Boys Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-03	Sample Name: 26 B Girls Faucet R Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-04	Sample Name: 26 B Staff girls Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-05	Sample Name: Rm 26 faucet Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	7.4	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-06	Sample Name: Rm 14 Girls Right Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-07	Sample Name: Rm 13 Boys Right Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	02/28/17 16:38	
7031003-08	Sample Name: Rm 1 Girls RR Right Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	30.5	ppb	2.0	20 ppb	02/28/17 16:38 MCLE	
7031003-09	Sample Name: Rm 5 faucet Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	29.8	ppb	2.0	20 ppb	02/28/17 16:38 MCLE	
7031003-10	Sample Name: Rm 5 bubbler Sampled: 1/31/17 5:35							Matrix: Water
+Lead	1030	EPA 200.9	17.4	ppb	2.0	20 ppb	02/28/17 16:38	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017
Received: 01/31/2017
Sampled By:
Work Order: 7031003


**C
L
I
E
N
T**
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Woodward

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7031003-11	Sample Name: Staff workroom copier Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	34.9	ppb	2.0	20 ppb	02/28/17 16:38 MCLE
7031003-12	Sample Name: Staff workroom copier #2 Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	23.4	ppb	2.0	20 ppb	02/28/17 16:38 MCLE
7031003-13	Sample Name: Staff RR Cafe Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	24.1	ppb	2.0	20 ppb	02/28/17 16:38 MCLE
7031003-14	Sample Name: Boys RR Cafe Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	02/28/17 16:38
7031003-15	Sample Name: Girls RR Cafe Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	10.6	ppb	2.0	20 ppb	02/28/17 16:38
7031003-16	Sample Name: Girls RR Breezeway R Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38
7031003-17	Sample Name: Boys RR Breezeway R Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/28/17 16:38
7031003-18	Sample Name: Kitchen food prep R Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	02/28/17 16:38
7031003-19	Sample Name: Kitchen sink - handwash Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	02/28/17 16:38
7031003-20	Sample Name: Boys RR Rm 6 R Sampled: 1/31/17 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	15.1	ppb	2.0	20 ppb	02/28/17 16:38



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017
Received: 01/31/2017
Sampled By:
Work Order: 7031003

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Woodward

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director

