

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

TTSD Note:
The specific results are shown in parts per billion ("ppb"). The results were obtained following protocols specified by the U.S. Environmental Protection Agency ("EPA") and the Oregon Health Authority.
Based on this sample event, there are no results that exceed EPA's recommended level of 20 ppb. For this set of data, "ND" means no detection, which represents results that are less than 2 ppb.

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 11/09/2016
Sampled By: P. Wentz
Work Order: 6314002

**C
L
I
E
N
T**
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017


Project:
Project # : N/A
Sample Type :

Sampling Location: Templeton

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6314002-01	Sample Name: Gym Left Fountain Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-02	Sample Name: Rm 8 faucet Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-03	Sample Name: Rm 8 Bubbler Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-04	Sample Name: Rm 5 faucet Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	9.7	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-05	Sample Name: Rm 5 bubbler Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-06	Sample Name: Rm 23 faucet Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-07	Sample Name: Rm 23 bubbler Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-08	Sample Name: Rm 17 faucet Sampled: 11/9/16 5:15							Matrix: Water
+Lead	1030	EPA 200.9	18.5	ppb	2.0	20 ppb	12/14/16 16:30	
6314002-09	Sample Name: Rm 17 bubbler Sampled: 11/9/16 5:45							Matrix: Water
+Lead	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	12/14/16 16:30	

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016

Received: 11/09/2016

Sampled By: P. Wentz

Work Order: 6314002

C **Tigard-Tualatin SD**
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Templeton

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director