



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

TTSD Note:

The specific results are shown in parts per billion ("ppb"). The results were obtained following protocols specified by the U.S. Environmental Protection Agency ("EPA") and the Oregon Health Authority.

Based on this sample event, there are no results that exceed EPA's recommended level of 20 ppb. For this set of data, "ND" means no detection, which represents results that are less than 2 ppb.

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-01	Sample Name: D.C. Caf. RR Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-02	Sample Name: D.C. Kitchen DW Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-03	Sample Name: D.C. Kitchen HW Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	12/02/16 15:50
6300013-04	Sample Name: D.C. Kitchen FP Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-05	Sample Name: D.C. Gym Entry WF Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-06	Sample Name: D.C. Gym Entry GRR 1 Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-07	Sample Name: D.C. Gym Entry GRR 2 Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-08	Sample Name: D.C. Gym Entry BRR 1 Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-09	Sample Name: D.C. Gym Entry BRR 2 Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6300013-10	Sample Name: D.C. Music Room Sampled: 10/26/16 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	12/02/16 15:50



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6300013-11	Sample Name: D.C. Room 20 Sampled: 10/26/16 5:00							Matrix: Water
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-12	Sample Name: D.C. Room 20 BB Sampled: 10/26/16 5:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-13	Sample Name: D.C. Room 19 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-14	Sample Name: D.C. Room 19 BB Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-15	Sample Name: D.C. Room 18 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-16	Sample Name: D.C. Room 18 BB Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-17	Sample Name: D.C. Room 17 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-18	Sample Name: D.C. Room 17 BB Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-19	Sample Name: D.C. Room 16 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-20	Sample Name: D.C. Room 16 BB Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6300013-21	Sample Name: D.C. East BRR 1 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-22	Sample Name: D.C. East BRR 2 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-23	Sample Name: D.C. East GRR 1 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-24	Sample Name: D.C. East GRR 2 Sampled: 10/26/16 5:30							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-25	Sample Name: D.C. East WF Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-26	Sample Name: D.C. East SRR Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-27	Sample Name: D.C. Room 21 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-28	Sample Name: D.C. Room 21 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-29	Sample Name: D.C. Room 22 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-30	Sample Name: D.C. Room 22 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6300013-31	Sample Name: D.C. Room 23 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-32	Sample Name: D.C. Room 23 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50	
6300013-33	Sample Name: D.C. Room 24 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-34	Sample Name: D.C. Room 24 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-35	Sample Name: D.C. Room 25 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-36	Sample Name: D.C. Room 25 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-37	Sample Name: D.C. Room 26 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-38	Sample Name: D.C. Room 26 BB Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-39	Sample Name: D.C. West WF 1 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23	
6300013-40	Sample Name: D.C. West WF 2 Sampled: 10/26/16 6:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-41	Sample Name: D.C. Room 14 Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/05/16 17:23
6300013-42	Sample Name: D.C. Room 14 BB Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-43	Sample Name: D.C. Room 14 RR Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-44	Sample Name: D.C. Office RR Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-45	Sample Name: D.C. Staff Room Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-46	Sample Name: D.C. Health Room Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-47	Sample Name: D.C. Health Room RR Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-48	Sample Name: D.C. East GRR 1 Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-49	Sample Name: D.C. East GRR 2 Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/05/16 17:23
6300013-50	Sample Name: D.C. East BRR 1 Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-51	Sample Name: D.C. East BRR 2 Sampled: 10/26/16 6:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-52	Sample Name: D.C. Room 12 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-53	Sample Name: D.C. Room 12 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-54	Sample Name: D.C. Room 11 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-55	Sample Name: D.C. Room 11 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-56	Sample Name: D.C. Room 10 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-57	Sample Name: D.C. Room 10 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-58	Sample Name: D.C. Room 9 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/05/16 17:23
6300013-59	Sample Name: D.C. Room 9 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-60	Sample Name: D.C. Room 8 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-61	Sample Name: D.C. Room 8 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-62	Sample Name: D.C. Room 7 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/05/16 17:23
6300013-63	Sample Name: D.C. Room 7 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-64	Sample Name: D.C. 8-B WR Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	10.3	ppb	2.0	20 ppb	12/05/16 17:23
6300013-65	Sample Name: D.C. 8-B WR BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6300013-66	Sample Name: D.C. East Staff RR Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	12/05/16 17:23
6300013-67	Sample Name: D.C. East End WF Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-68	Sample Name: D.C. Room 6 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	12/06/16 17:01
6300013-69	Sample Name: D.C. Room 6 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-70	Sample Name: D.C. Room 5 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/06/16 17:01



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-71	Sample Name: D.C. Room 5 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-72	Sample Name: D.C. Room 4 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/06/16 17:01
6300013-73	Sample Name: D.C. Room 4 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-74	Sample Name: D.C. Room 3 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-75	Sample Name: D.C. Room 3 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-76	Sample Name: D.C. Room 2 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-77	Sample Name: D.C. Room 2 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-78	Sample Name: D.C. Room 1 Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-79	Sample Name: D.C. Room 1 BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-80	Sample Name: D.C. Room 1-6 WR Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	10.3	ppb	2.0	20 ppb	12/06/16 17:01



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6300013-81	Sample Name: D.C. Room 1-6 WR BB Sampled: 10/26/16 7:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-82	Sample Name: D.C. Room 15-17 WR Sampled: 10/26/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	12/06/16 17:01
6300013-83	Sample Name: D.C. Room 15-17 WR BB Sampled: 10/26/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-84	Sample Name: D.C. Room 24-26 WR Sampled: 10/26/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	12/06/16 17:01
6300013-85	Sample Name: D.C. Room 24-26 WR BB Sampled: 10/26/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	12/06/16 17:01
6300013-86	Sample Name: D.C. Room 15 Sampled: 10/26/16 5:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-87	Sample Name: D.C. Room 15 BB Sampled: 10/26/16 5:30		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/06/16 17:01
6300013-88	Sample Name: D.C. Library Sampled: 10/26/16 7:30		Matrix: Water				
+Lead	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	12/06/16 17:01

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/09/2016
Received: 10/26/2016
Sampled By: Dani Gavaza
Work Order: 6300013

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Deer Creek

Lab Number

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director