

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/28/2017  
Received: 01/06/2017  
Sampled By:  
Work Order: 7006015

**C**  
**L**  
**I**  
**E**  
**N**  
**T**

**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Bridgeport

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7006015-01</b>	<b>Sample Name:</b> Mens N F <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.9	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-02</b>	<b>Sample Name:</b> Womens N F <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-03</b>	<b>Sample Name:</b> Boys N F 1 <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-04</b>	<b>Sample Name:</b> Girls N F 1 <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-05</b>	<b>Sample Name:</b> Rm 28 F <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-06</b>	<b>Sample Name:</b> Rm 28 BB <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-07</b>	<b>Sample Name:</b> Rm 24 F <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>30.5</b>	ppb	2.0	20 ppb	02/27/17 17:08 <b>MCL E</b>
<b>7006015-08</b>	<b>Sample Name:</b> Rm 24 BB <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-09</b>	<b>Sample Name:</b> Rm 23 F <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-10</b>	<b>Sample Name:</b> Rm 23 BB <b>Sampled:</b> 1/6/17 4:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	02/27/17 17:08



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/28/2017  
Received: 01/06/2017  
Sampled By:  
Work Order: 7006015

**C** Tigard-Tualatin SD  
**L** Attn: Phil Wentz  
**I** 6960 SW Sandburg St.  
**E** Tigard OR, 97223  
**N** Phone: (503) 431-4017  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Bridgeport

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7006015-11</b>	<b>Sample Name:</b> Lean Spec - F <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	21.8	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-12</b>	<b>Sample Name:</b> Rm 25 F <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	13.6	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-13</b>	<b>Sample Name:</b> Rm 25 BB <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-14</b>	<b>Sample Name:</b> Rm 18 F <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-15</b>	<b>Sample Name:</b> Rm 18 BB <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-16</b>	<b>Sample Name:</b> W Boys F 1 <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	30.8	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-17</b>	<b>Sample Name:</b> W Girls F 1 <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	17.5	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-18</b>	<b>Sample Name:</b> Rm 4 BB <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	28.1	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-19</b>	<b>Sample Name:</b> Rm 4 F <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	90.7	ppb	8.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-20</b>	<b>Sample Name:</b> Rm 6 BB <b>Sampled:</b> 1/6/17 4:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	44.7	ppb	4.0	20 ppb	02/27/17 17:08 MCLE



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 02/28/2017  
Received: 01/06/2017  
Sampled By:  
Work Order: 7006015


**C**  
**L**  
**I**  
**E**  
**N**  
**T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Bridgeport

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7006015-21</b>	<b>Sample Name:</b> Rm6 F <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	39.1	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-22</b>	<b>Sample Name:</b> Rm 3 F <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	63.6	ppb	4.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-23</b>	<b>Sample Name:</b> Rm 3 BB <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	15.6	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-24</b>	<b>Sample Name:</b> Rm 1 BB <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	19.7	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-25</b>	<b>Sample Name:</b> Rm 1 F <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	48.8	ppb	4.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-26</b>	<b>Sample Name:</b> Rm 7 F <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	27.4	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-27</b>	<b>Sample Name:</b> Rm 7 BB <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	13.1	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-28</b>	<b>Sample Name:</b> Rm 10 BB <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	23.2	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-29</b>	<b>Sample Name:</b> Rm 10 F <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	23.2	ppb	2.0	20 ppb	02/27/17 17:08 MCLE
<b>7006015-30</b>	<b>Sample Name:</b> E Girls F 1 <b>Sampled:</b> 1/6/17 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7.2	ppb	2.0	20 ppb	02/27/17 17:08



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/28/2017  
Received: 01/06/2017  
Sampled By:  
Work Order: 7006015

**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Bridgeport

### Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>7006015-31</b>	<b>Sample Name:</b> E Boys F 1 <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	16.3	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-32</b>	<b>Sample Name:</b> Cafeteria Boys F 1 <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-33</b>	<b>Sample Name:</b> Cafeteria Staff F <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-34</b>	<b>Sample Name:</b> Cafeteria Girls F 1 <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-35</b>	<b>Sample Name:</b> Atrium Boys F 1 <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-36</b>	<b>Sample Name:</b> Atrium Girls F 1 <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-37</b>	<b>Sample Name:</b> Gym Boys F <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	02/27/17 17:08
<b>7006015-38</b>	<b>Sample Name:</b> Gym Girls F <b>Sampled:</b> 1/6/17 5:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/27/17 17:08

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL

**MRL** = Minimum Reporting Limit

**MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.



Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/28/2017  
Received: 01/06/2017  
Sampled By:  
Work Order: 7006015

**C** **Tigard-Tualatin SD**  
**L** Attn: Phil Wentz  
**I** 6960 SW Sandburg St.  
**E** Tigard OR, 97223  
**N** Phone: (503) 431-4017  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Bridgeport

---

## Lab Number

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director

