



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

TTSD Note:
The specific results are shown in parts per billion ("ppb"). The results were obtained following protocols specified by the U.S. Environmental Protection Agency ("EPA") and the Oregon Health Authority. Based on this sample event, there are no results that exceed EPA's recommended level of 20 ppb. For this set of data, "ND" means no detection, which represents results that are less than 2 ppb.

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6301029-01	Sample Name: Nurse - F Sampled: 10/26/16 5:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-02	Sample Name: Nurse RR Sampled: 10/26/16 5:00							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-03	Sample Name: Office RR Sampled: 10/26/16 5:10							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-04	Sample Name: Staff lunchroom Sampled: 10/26/16 5:10							Matrix: Water
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-05	Sample Name: Staff lunchroom hot wtr Sampled: 10/26/16 5:10							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-06	Sample Name: 209 - F Sampled: 10/26/16 5:16							Matrix: Water
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-07	Sample Name: 209 - B Sampled: 10/26/16 5:16							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-08	Sample Name: 211 RR Sampled: 10/26/16 5:16							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-09	Sample Name: 212 RR Sampled: 10/26/16 5:18							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41	
6301029-10	Sample Name: 210 - F Sampled: 10/26/16 5:21							Matrix: Water
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	11/23/16 15:41	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L
I Attn: Phil Wentz
E 6960 SW Sandburg St.
N Tigard OR, 97223
T Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-11	Sample Name: 210 -B Sampled: 10/26/16 5:21		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-12	Sample Name: 213 - F Sampled: 10/26/16 5:24		Matrix: Water				
+Lead	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	11/23/16 15:41
6301029-13	Sample Name: 213 - B Sampled: 10/26/16 5:24		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-14	Sample Name: 222 - F Sampled: 10/26/16 5:27		Matrix: Water				
+Lead	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	11/23/16 15:41
6301029-15	Sample Name: 214 - F Sampled: 10/26/16 5:28		Matrix: Water				
+Lead	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	11/23/16 15:41
6301029-16	Sample Name: 214 - B Sampled: 10/26/16 5:28		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-17	Sample Name: 215 RR-1 Sampled: 10/26/16 5:29		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-18	Sample Name: 218 RR-1 Sampled: 10/26/16 5:32		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-19	Sample Name: 218 RR-2 Sampled: 10/26/16 5:32		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301029-20	Sample Name: 219 RR-1 Sampled: 10/26/16 5:34		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
6301029-21	Sample Name: 219 RR-2 Sampled: 10/26/16 5:34							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-22	Sample Name: 235 - F Sampled: 10/26/16 5:39							Matrix: Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-23	Sample Name: 235 - B Sampled: 10/26/16 5:39							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-24	Sample Name: 236 - F Sampled: 10/26/16 5:41							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-25	Sample Name: 236- B Sampled: 10/26/16 5:41							Matrix: Water
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-26	Sample Name: 234 - F2 Sampled: 10/26/16 5:43							Matrix: Water
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-27	Sample Name: 234 - B2 Sampled: 10/26/16 5:43							Matrix: Water
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-28	Sample Name: 234 - F1 Sampled: 10/26/16 5:45							Matrix: Water
+Lead	1030	EPA 200.9	4.3	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-29	Sample Name: 234 -B1 Sampled: 10/26/16 5:45							Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11	
6301029-30	Sample Name: 237 - F Sampled: 10/26/16 5:49							Matrix: Water
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	12/27/16 17:11	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L
I Attn: Phil Wentz
E 6960 SW Sandburg St.
N Tigard OR, 97223
T Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-31	Sample Name: 237 - B Sampled: 10/26/16 5:49		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-32	Sample Name: 238 - F Sampled: 10/26/16 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/27/16 17:11
6301029-33	Sample Name: 238 - B Sampled: 10/26/16 5:51		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-34	Sample Name: Kitchen - 1 Sampled: 10/26/16 5:58		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-35	Sample Name: Kitchen - 2 Sampled: 10/26/16 5:58		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-36	Sample Name: Kitchen - dishwasher Sampled: 10/26/16 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-37	Sample Name: Kitchen handwasher 1 Sampled: 10/26/16 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/27/16 17:11
6301029-38	Sample Name: Kitchen handwasher 2 Sampled: 10/26/16 5:55		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-39	Sample Name: Kitchen Island Sampled: 10/26/16 5:59		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-40	Sample Name: 231 - RR - 1 Sampled: 10/26/16 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

**C
L
I
E
N
T**
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-41	Sample Name: 231 RR - 2 Sampled: 10/26/16 6:00						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-42	Sample Name: 231 RR - 3 Sampled: 10/26/16 6:00						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-43	Sample Name: 230 RR - 1 Sampled: 10/26/16 6:05						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-44	Sample Name: 230 RR - 2 Sampled: 10/26/16 6:05						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-45	Sample Name: 230 RR - 3 Sampled: 10/26/16 6:05						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-46	Sample Name: 242 - F Sampled: 10/26/16 6:08						Matrix: Water
+Lead	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	12/27/16 17:11
6301029-47	Sample Name: 252 - F Sampled: 10/26/16 6:08						Matrix: Water
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/27/16 17:11
6301029-48	Sample Name: 252 - B Sampled: 10/26/16 6:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-49	Sample Name: 253 - F Sampled: 10/26/16 6:11						Matrix: Water
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/27/16 17:11
6301029-50	Sample Name: 253 - B Sampled: 10/26/16 6:11						Matrix: Water
+Lead	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	12/27/16 17:11



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-51	Sample Name: 251 - F2 Sampled: 10/26/16 6:13		Matrix: Water				
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/27/16 17:11
6301029-52	Sample Name: 251 - B2 Sampled: 10/26/16 6:13		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-53	Sample Name: 251 - F1 Sampled: 10/26/16 6:17		Matrix: Water				
+Lead	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	12/27/16 17:11
6301029-54	Sample Name: 251 - B1 Sampled: 10/26/16 6:17		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/27/16 17:11
6301029-55	Sample Name: 254 F Sampled: 10/26/16 6:17		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/27/16 17:11
6301029-56	Sample Name: 254 B Sampled: 10/26/16 6:17		Matrix: Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	12/27/16 17:11
6301029-57	Sample Name: 255 F Sampled: 10/26/16 6:20		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	12/27/16 17:11
6301029-58	Sample Name: 255 B Sampled: 10/26/16 6:20		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-59	Sample Name: 256 F Sampled: 10/26/16 6:21		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/28/16 17:30
6301029-60	Sample Name: 256 B Sampled: 10/26/16 6:21		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-61	Sample Name: 128 RR-1 Sampled: 10/26/16 6:26		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-62	Sample Name: 128 RR-2 Sampled: 10/26/16 6:26		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-63	Sample Name: 127 RR-1 Sampled: 10/26/16 6:27		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-64	Sample Name: 127 RR-2 Sampled: 10/26/16 6:27		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-65	Sample Name: 123 - F Sampled: 10/26/16 6:29		Matrix: Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	12/28/16 17:30
6301029-66	Sample Name: 123 - B Sampled: 10/26/16 6:29		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-67	Sample Name: 122 F-1 Sampled: 10/26/16 6:31		Matrix: Water				
+Lead	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	12/28/16 17:30
6301029-68	Sample Name: 122 B-1 Sampled: 10/26/16 6:31		Matrix: Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	12/28/16 17:30
6301029-69	Sample Name: 122 F-2 Sampled: 10/26/16 6:33		Matrix: Water				
+Lead	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	12/28/16 17:30
6301029-70	Sample Name: 122 B-2 Sampled: 10/26/16 6:33		Matrix: Water				
+Lead	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/28/16 17:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

**C
L
I
E
N
T**
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-71	Sample Name: 124 F Sampled: 10/26/16 6:35		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/28/16 17:30
6301029-72	Sample Name: 124 B Sampled: 10/26/16 6:35		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-73	Sample Name: 125 F Sampled: 10/26/16 6:38		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	12/28/16 17:30
6301029-74	Sample Name: 125 B Sampled: 10/26/16 6:38		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-75	Sample Name: 126 F Sampled: 10/26/16 6:38		Matrix: Water				
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/28/16 17:30
6301029-76	Sample Name: 126 B Sampled: 10/26/16 6:38		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/28/16 17:30
6301029-77	Sample Name: 134 F-2 Sampled: 10/26/16 6:42		Matrix: Water				
+Lead	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	12/28/16 17:30
6301029-78	Sample Name: 134 B-2 Sampled: 10/26/16 6:42		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/29/16 17:02
6301029-79	Sample Name: 134 F-1 Sampled: 10/26/16 6:42		Matrix: Water				
+Lead	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	12/29/16 17:02
6301029-80	Sample Name: 134 B-1 Sampled: 10/26/16 6:42		Matrix: Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/29/16 17:02



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L
I Attn: Phil Wentz
E 6960 SW Sandburg St.
N Tigard OR, 97223
T Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-81	Sample Name: 135 F Sampled: 10/26/16 6:46		Matrix: Water				
+Lead	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	12/29/16 17:02
6301029-82	Sample Name: 135 B Sampled: 10/26/16 6:46		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/29/16 17:02
6301029-83	Sample Name: 136 F Sampled: 10/26/16 6:48		Matrix: Water				
+Lead	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	12/29/16 17:02
6301029-84	Sample Name: 136 B Sampled: 10/26/16 6:48		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-85	Sample Name: 137 F Sampled: 10/26/16 6:50		Matrix: Water				
+Lead	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/09/16 15:15
6301029-86	Sample Name: 138 F Sampled: 10/26/16 6:50		Matrix: Water				
+Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	12/09/16 15:15
6301029-87	Sample Name: 138 B Sampled: 10/26/16 6:50		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-88	Sample Name: 149 Staff RR Sampled: 10/26/16 6:53		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-89	Sample Name: 151 F1 Sampled: 10/26/16 6:54		Matrix: Water				
+Lead	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	12/09/16 15:15
6301029-90	Sample Name: 151 F2 Sampled: 10/26/16 6:54		Matrix: Water				
+Lead	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	12/09/16 15:15



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301029-91	Sample Name: 151 B2 Sampled: 10/26/16 6:54						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-92	Sample Name: 152 F Sampled: 10/26/16 6:54						Matrix: Water
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	12/09/16 15:15
6301029-93	Sample Name: 152 B Sampled: 10/26/16 6:54						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-94	Sample Name: 153 F Sampled: 10/26/16 7:00						Matrix: Water
+Lead	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	12/09/16 15:15
6301029-95	Sample Name: 153 B Sampled: 10/26/16 7:00						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-96	Sample Name: 154 F Sampled: 10/26/16 7:01						Matrix: Water
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	12/09/16 15:15
6301029-97	Sample Name: 154 B Sampled: 10/26/16 7:01						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/09/16 15:15
6301029-98	Sample Name: 155 F Sampled: 10/26/16 7:03						Matrix: Water
+Lead	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	12/12/16 15:59
6301029-99	Sample Name: 155 B Sampled: 10/26/16 7:03						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/12/16 15:59
6301030-01	Sample Name: 156 F Sampled: 10/26/16 7:05						Matrix: Water
+Lead	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	11/21/16 17:09



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/30/2016
Received: 10/26/2016
Sampled By: Lisa Cresap
Work Order: Multiple Work Orders

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Alberta Rider

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301030-02	Sample Name: 156 B Sampled: 10/26/16 7:05						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-03	Sample Name: 130 RR 1 Sampled: 10/26/16 7:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-04	Sample Name: 130 RR 2 Sampled: 10/26/16 7:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-05	Sample Name: 130 RR 3 Sampled: 10/26/16 7:08						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-06	Sample Name: 129 RR 1 Sampled: 10/26/16 7:10						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-07	Sample Name: 129 RR 2 Sampled: 10/26/16 7:10						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09
6301030-08	Sample Name: 129 RR 3 Sampled: 10/26/16 7:10						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/21/16 17:09

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director